



EMERGENCY LOCKDOWN

OVERVIEW

DSX can accommodate the quick lockdown of a system in response to incident or emergency. The Lockdown occurs without the need of programming or lengthy downloads. A Lockdown response to an incident or emergency will typically secure all perimeter doors and possibly all or specific interior doors. This can be in one building or in all buildings of a campus, facility, or even a district. Locking down doors is the first action taken but is not necessarily the only action required. This document will discuss the different triggers (activations) and different actions (responses) but is geared towards the use of the DSX Mobile Application for the trigger. This information will help you engineer the best possible response for an emergency lockdown situation.

Here are questions that will help determine what the customer wants and needs. After most of the questions you may find additional information that may help qualify and answer that question. Once we determine what the requirements are, we will discuss how to implement them in the configuration document.

DOORS

What Doors should be locked down?

>Perimeter Doors

>Internal Doors

REMOTE RELEASE BUTTONS

Which of these doors have remote release buttons?

CARD READERS & KEYPADS

Should any readers be disabled?

>Which readers?

Should any readers be elevated to Card + PIN during a Lockdown?

>Which readers?

CREDENTIALS

Disable Cards

>Should any Cards be disabled?

>Which Cards or Groups of Card Holders should be disabled?

Enable Cards (often used for First Responder access)

>Should any Cards be enabled?

>Which Cards or Groups of Card Holders should be enabled?

>What doors do the enabled cards need to unlock?

INPUTS

Should any Inputs (Alarm Points) that are normally disarmed be armed during a Lockdown to generate an alarm if opened during a Lockdown?

>Which inputs?

OUTPUTS

What needs to be turned on or off during a Lockdown? (Security gate, parking lot gates, lights, strobes, etc.)

>Do Outputs need to activate an alarm panel or digital communicator?

>Should an Output be used to trip an Input on a DSX Controller so that Alarm Emails and Text Messages are sent from the Comm Server?

>What Emails or Phone numbers will be alerted?

LOCKDOWN TRIGGER METHOD

How will the Lockdown be Triggered?

DSX Mobile App?

Override Group Icon in Workstation?

Local Action such as Card Read or Panic Button for a Location specific Lockdown?

RESET

How will the System be reset from the Lockdown?

Options:

Global Lockdown can be reset from:

>DSX Mobile App

>DSX Software

Location Specific Lockdowns can be reset from:

>DSX Software

>Reset of Panic Button

>Special Reset Card or Code used at a reader or keypad